

Island County Water Well Information



WellKey: 4J8

General Information

Owner Name (log): Devries Road Community Association (no log)

DOE Tag: AGA594 DOE NOI:

DOE ID


Well Address:

Well Parcel: [R23320-139-4240](#)

Served Parcel:

Horiz/Vert Accuracy: GPS / Survey

Site Type: Well



SWI Rating: Low Risk

Construction Information

Construction Date:

Driller Name: Unknown

LS Elevation: 397.04 ft. MSL

Depth Well:

TD Elevation: 30 ft. MSL

WL Measurements: [2 measurements \(Click to View\)](#)

WL Elevation: 109.51 ft. MSL

No Scanned
Water Well
Report Available

Water Quality Information

Water Samples: [31 samples \(Click to View\)](#)


Average/Median/Maximum Arsenic: 0.004 / 0.004 / 0.005 mg/l

Average/Median/Maximum Chloride: 18.43 / 18 / 31 mg/l

Average/Median/Maximum Hardness: 170.00 / 170 / 180 mg/l

Average/Median/Maximum Nitrate: 0.20 / 0.25 / 0.4 mg/l

Bacteria Samples (distribution): [288 samples \(Click to View\)](#)



Public Water System Information

Pws Name: Devries Road Community Assn

PwsID: [15948](#)

Approved Connects: 42

Pws Source #: SO# 1

Pws Source Name: WELL #1 AGA594

Note: Underlined items in **bright blue** are hyperlinks to additional information / resources.

Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/30/2020